


EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com



Attn: TRC Environmental Consultants

1430 Broadway

10th Floor

New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017/ New York City Law Department/ 100 Church St.

Customer ID: TRCE51

Customer PO:

Received: 03/29/03 10:04 PM

EMSL Order: 030305290

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD032903LW2001 Vertical Surface Filling Cabinet Vests/Filing Rm	0001	3/31/03	144 in ²	<10.0 µg/ft ²
ZD032903LW2002 Horizontal Surface top of the Cabinet/Suplay Rm	0002	3/31/03	144 in ²	<10.0 µg/ft ²
ZD032903LW2003 Horizontal Surface top of the Cabinet/Suplay Rm	0003	3/31/03	144 in ²	<10.0 µg/ft ²
ZD032903LW2004 Field Blank	0004	3/31/03	n/a	<10.0 µg/wipe

Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581