

Table
 Asbestos Microvac (ASTM 5575)
 Soft Goods
 New York City Law Department
 100 Church Street
 New York

* Sample ID : Lab Sample ID : Sample Date : * Sample Type : Floor: Surface Type: Location:	Geometric Mean	MV2008 8 8/13/2002 Microvac 20 Chair with cloth Northwest section, Room 8-1677	MV2009 9 8/13/2002 Microvac 20 Chair with cloth East middle section, Room 8-1511
CONSTITUENTS ASBESTOS (structures/cm²)	446	<891	<891

* Post Cleaning Target = <10,000 str/cm²
 (structures per square centimeter) individual
 sample and geometric mean of <1,000
 str/cm²

CITY_21MC100_012558321