

Table
 Lead Wipe Samples - Office
 Hard Surfaced Furniture
 New York City Law Department
 100 Church Street
 New York

Sample ID :	LW2001	LW2002	LW2003	LW2013	LW2014
Lab Sample ID :	1	2	3	13	14
Sample Date :	8/9/2002	8/9/2002	8/9/2002	8/10/2002	8/10/2002
Sample Type :	Wipe	Wipe	Wipe	Wipe	Wipe
Floor:	20	20	20	20	20
Surface Description:	Top of computer monitor	Top of kitchen counter	Top of metal desk	Top of table North section, middle, small conference room	Top of table West section, middle, Room 8-2614
Location:	Room 8-1412	Kitchen	Room 8-1472		
CONSTITUENTS					
LEAD (ug/ft ²)	125	<83.6	166	209	<84

Post cleaning target <40 ug/ft²

< = less than