

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants

1430 Broadway

10th Floor

New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department / 100 Church St.

Customer ID: TRCE51

Customer PO:


Received: 03/15/03 10:53 AM

EMSL Order: 030304175

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD031503LW2001 Inside HVAC Duct - Supply Air/12x12/20th Fl. W. Side	0001	3/15/03	144 in ²	<10.0 µg/ft ²
ZD031503LW2002 Inside HVAC Duct - Supply Air/12x12/20th Fl. NW Side	0002	3/15/03	144 in ²	<10.0 µg/ft ²
ZD031503LW2003 Inside HVAC Duct - Supply Air/12x12/20th Fl. Cent. of N	0003	3/15/03	144 in ²	<10.0 µg/ft ²


Laboratory Manager
or other approved signatory

Reporting time is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #1025B1