

Table
 Asbestos Microvac (ASTM 5575)
 Supply Ducts
 New York City Law Department
 100 Church Street
 New York

* Sample ID : Lab Sample ID : Sample Date : * Sample Type : Floor: Surface Type: Location:	Geometric Mean	MV2001 1 8/10/2002 Microvac 20 Supply air duct Northeast women's toilet vestibule	MV2002 2 8/10/2002 Microvac 20 Supply air duct Northeast, women's toilet	MV2003 3 8/10/2002 Microvac 20 Supply air duct Northwest, men's toilet	MV2004 4 8/10/2002 Microvac 20 Supply air duct Southeast, men's toilet
CONSTITUENTS					
ASBESTOS (structures/cm²)	757	2,140	<1,070	<1,070	<1,070

* Post Cleaning Target = <10,000 str/cm²
 (structures per square centimeter) individual
 sample and geometric mean of <1,000
 str/cm²