

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
 1430 Broadway
 10th Floor
 New York, NY 10018

Fax: (212) 221-7840 Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Department / 100
 Church St. / Ambient

Customer ID: TRCE51
 Customer PO:
 Received: 02/28/03 3:55 PM

EMSL Order: 030303182
 EMSL Project ID:
 Analysis Date: 2/28/2003

Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
ZD022803ASBAI R2001 030303182-0001	20th Floor Exit to North Corridor	2/28/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
ZD022803ASBAI R2002 030303182-0002	20th Floor Exit to South Corridor	2/28/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD022803ASBAI R2003 030303182-0003	20th Floor Exit to North Corridor	2/28/2003	1520.71	<5.5	100	0.002	<7.0	<0.002	
ZD022803ASBAI R2004 030303182-0004	20th Floor Exit to South Corridor	2/28/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD022803ASBAI RFB05 030303182-0005	Blank	2/28/2003	0.00	<5.5	100		<7.0		Field Blank

Zeno Mezheritsky

Analyst

Laboratory Manager
 or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506, ALHA #102581)

PCM-2