

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattan@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017/ NEW YORK CITY LAW
DEPARTMENT/ 100 CHURCH ST. PHASE II

Customer ID: TRCE51

Customer PO:

Received: 03/15/03 11:29 PM

EMSL Order: 030304233

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description		Lab ID	Analyzed	Area Sampled	Lead Concentration
GS031503LW2001	20TH FLOOR/ NORTH HALLWAY- OUTSIDE W. MEN'S BATH	0001	3/17/03	144 in ²	<10.0 µg/ft ²
GS031503LW2002	20TH FLOOR/ NORTH HALLWAY- ELEVATOR BANK	0002	3/17/03	144 in ²	<10.0 µg/ft ²
GS031503LW2003	20TH FLOOR/ NORTH HALLWAY- OUTSIDE COPY CENTER	0003	3/17/03	144 in ²	<10.0 µg/ft ²
GS031503LW2004	FIELD BLANK	0004	3/17/03	n/a	<10.0 µg/wipe

Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581