

Summary of Asbestos Analyses at PS/IS 89 Performed by ATC for the Board of Education (Through January 27, 2002)				
Sample Date	Number of Samples Collected (Inside/Outside)	Number of Samples with Asbestos Structures Detected	Maximum Asbestos Concentration (structures/mm²)	All Samples below AHERA Clearance Level of 70 structures/mm²?
January 27, 2002	10 inside 6 outside	0 inside 1 outside	22 str/mm ²	Yes
January 26, 2002	10 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 25, 2002	10 inside 6 outside	1 inside 0 outside	22 str/mm ²	Yes
January 24, 2002	10 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 23, 2002	10 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 22, 2002	8 inside 3 outside	0 inside 0 outside	None Detected	Yes
January 21, 2002	8 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 19, 2002	3 inside 3 outside	0 inside 0 outside	None Detected	Yes
January 18, 2002	6 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 17, 2002	6 inside 6 outside	0 inside 0 outside	None Detected	Yes
January 16, 2002	6 inside 6 outside	1 inside 1 outside (1 structure each)	22 str/mm ²	Yes
January 12, 2002	4 outside	0 outside	None Detected	Yes
January 10, 2002	45 inside	0 inside	None Detected	Yes

Summary of Respirable Particulate (PM2.5) Measurements at PS/IS 89 (Through January 25, 2002)					
Date	Number of Readings (Inside/Outside)	Range of PM2.5 Measurements (ug/m ³)	Average PM2.5 Measurement (ug/m ³)	Number of Measurements above 40 ug/m ³	Number of Measurements above 65 ug/m ³
January 25, 2002	72 inside 8 outside	6-28 (inside) 9-30 (outside)	13 (inside) 18 (outside)	0 (inside) 0 (outside)	0 (inside) 0 (outside)
January 24, 2002	74 inside 6 outside	21-63 (inside) 54-83 (outside)	42 (inside) 66 (outside)	40 (inside) 6 (outside)	0 (inside) 2 (outside)
January 23, 2002	86 inside 4 outside	9-17 (inside) 13-20 (outside)	11.3 (inside) 16 (outside)	0 inside 0 outside	0 inside 0 outside
January 22, 2002	69 inside 4 outside	8-38 (inside) 19-61 (outside)	20.1 (inside) 38.8 (outside)	0 (inside) 2 (outside)	0 (inside) 0 (outside)
January 21, 2002	59 inside 2 outside	31-61 inside 70-71 (outside)	39.9 (inside) 70.5 (outside)	17 (inside) 2 (outside)	0 (inside) 2 (outside)
January 18, 2002	48 inside 2 outside	18-30 (inside) 35-36 (outside)	23.6 (inside) 35.5 (outside)	0 (inside) 0 (outside)	0 (inside) 0 (outside)
January 17, 2002	48 inside 2 outside	19-44 inside 41-46 (outside)	28.8 (inside) 43.5 (outside)	2 (inside) 2 (outside)	0 (inside) 0 (outside)
January 16, 2002	23 inside 7 outside	5-13 (inside) 10-13 (outside)	8.6 (inside) 11.7 (outside)	0 (inside) 0 (outside)	0 (inside) 0 (outside)
January 15, 2002	7 inside 3 outside	30-60 (outside) 80-82 (outside)	45.5 (inside) 80.7 (outside)	3 (inside) 3 (outside)	0 (inside) 3 (outside)
January 11, 2002	60 inside 1 outside	7-18 (inside) 36 (outside)	9.2 (inside) 36 (outside)	0 (inside) 0 (outside)	0 (inside) 0 (outside)