

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/6/01 5:00:00 AM

ATC Group #: 5839

Analysis Date: 11/6/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: P.S. 89M
201 Warren Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
04 - 5839 -1	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 - 5839 -2	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 - 5839 -3	1890.00	0.0450	0	AMOSITE	0	1	0.0045	22.24	0.0045	
07 - 5839 -4	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
08 - 5839 -5	1890.00	0.0450	0	CHRYSTILE	0	1	0.0045	22.24	0.0045	
09 - 5839 -6	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 - 5839 -7	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
11 - 5839 -8	1890.00	0.0450	0	CHRYSTILE	0	1	0.0045	22.24	0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879