

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6

TIME _____

LOCATION PS 89M 5th floor DATE 01/21/02 PROJECT NO. 19125-02 97

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside		42.2	49.3	469	0	70	0.0
506		69.4	30.8	471	0	38	0.0
502		71.2	28.3	467	0	49	0.0
501		71.5	25.8	456	0	31	0.0
hallway		71.6	26.7	502	0	60	0.0
Stair 3		71.7	27.7	509	0	49	0.0
508		72.5	27.5	498	0	35	0.0
504		71.3	27.6	482	0	40	0.0
517 Library		74.4	25.8	452	0	35	0.0
515		74.0	23.2	491	0	38	0.0
Guideline levels ASHRAE/AMBA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 01/21/02

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_014659957

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

TIME _____

LOCATION PS-89M 5 & 4 floors DATE 01/21/02 PROJECT NO. 19125-02

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
510		72.3	25.9	481	0	39	0.0
512		72.2	24.7	451	0	43	0.0
Stair 2		70.6	26.6	431	0	61	0.0
526		72.8	24.2	454	0	55	0.0
528		71.4	24.5	473	0	41	0.0
532		71.6	23.8	458	0	48	0.0
519		72.7	23.7	438	0	38	0.0
4th floor Stair 3		72.5	23.7	456	0	48	0.0
401		71.4	23.2	459	0	31	0.0
402		71.6	23.4	462	0	33	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: H. Pustay Date: 01/21/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6

TIME _____

LOCATION P.S. 89 4th floor DATE 01/21/02 PROJECT NO. 19125-02

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
404		72.8	23.8	449	0	39	0.0
406		71.9	22.9	451	0	29	0.0
Hallway		72.7	23.7	438	0	36	0.0
408		72.3	22.5	451	0	31	0.0
410		72.4	22.4	467	0	41	0.0
Stair 2		70.8	23.2	495	0	32	0.0
426		72.7	23.4	471	0	38	0.0
428		71.8	24.6	491	0	36	0.0
430		71.3	24.8	469	0	32	0.0
432		72.5	23.2	461	0	39	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 01/21/02

ATC ASSOCIATES, INC.

Page 4 of 6

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 89M 4th & 3rd floors DATE 01/21/02 PROJECT NO. 19125-02

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
419		70.9	23.6	448	0	31	0.0
Stair 1		69.3	24.4	457	0	35	0.0
332		69.4	24.5	455	0	38	0.0
319		67.8	24.6	469	0	39.	0.0
330		68.3	24.2	458	0	38	0.0
328		68.6	25.8	460	0	34	0.0
Gym		68.2	26.6	499	0	35	0.0
326		68.4	26.0	459	0	36	0.0
Hallway		68.5	26.2	460	0	41	0.0
316		69.8	26.5	461	0	36	0.0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Andaya Date: 01/21/02

ATC ASSOCIATES, INC.

Page 5 of 6

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 89 M 3rd & 1st floors DATE 01/21/02 PROJECT NO. 19125-02

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
312		68.3	25.7	456	0	34	0.0
310		68.5	25.6	459	0	31	0.0
308		68.7	25.5	457	0	35	0.0
306		67.7	25.3	458	0	33	0.0
304		67.8	25.0	471	0	35	0.0
Stair 3		67.6	26.2	461	0	39	0.0
301		68.5	26.4	458	0	34	0.0
302		67.8	25.6	471	0	36	0.0
1st floor Cafeteria		67.6	27.2	508	0	41	0.0
132		68.4	26.6	478	0	39	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Antez Date: 01/21/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

TIME _____

LOCATION _____

DATE 01/21/02

PROJECT NO. 19125-01

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
132B		69.3	26.5	463	0	36	0.0
132C		69.8	26.6	451	0	39	0.0
132D		69.3	26.4	473	0	38	0.0
134		68.7	26.5	488	0	40	0.0
Stair 1		67.7	27.4	490	0	57	0.0
128		69.9	26.6	459	0	39	0.0
1st floor lobby by 128		69.8	26.0	471	0	48	0.0
hallway by the cafeteria		68.6	27.4	479	0	51	0.0
Stair 3		69.5	26.8	478	0	61	0.0
1st floor lobby by elevator		69.9	26.6	481	0	60	0.0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Outside 42.2 30.0 470 0 71 0.0

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 01/21/02

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_014659962