


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 5TIME 8:00LOCATION PS89M DATE 1/17/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
South Side ^{of} Playground		45.5	25.4	438	0	46	0
North Side of Playground		45.9	28.0	430	0	41	0
South Side Exit		68.3	33.0	541	0	31	0
Elevator (Hall)		69.2	29.0	478	0	31	0
Cafeteria		67.1	24.8	454	0	23	0
Dance Room		67.5	24.2	460	0	23	0
Hall by Cafeteria		67.4	24.0	459	0	26	0
(Hall) North Exit to P.G. Side		67.9	24.4	499	0	27	0
132 (Hall)		68.4	24.0	462	0	29	0
North Exit		68.9	23.5	480	0	26	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/17/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 5TIME 8:25LOCATION 89M DATE 1/17/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501	1	74.2	21.9	465	0	19	0
502	1	75.2	20.9	449	0	26	0
Hall by stair #3	—	74.8	20.8	455	0	31	0
504	1	78.0	23.3	629	0	29	0
506	2	76.3	19.4	499	0	28	0
509 (Hall)	—	74.7	19.0	465	0	34	0
WINDOW #1 OPEN Hall by stair #2	—	71.7	19.1	433	0	36	0
528	3	72.5	20.2	499	0	28	0
519	3	71.7	20.0	533	0	26	0
532	3	72.0	20.0	464	0	26	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/17/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 5TIME 8:55LOCATION M89 DATE 1/17/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair # <u>1</u>	<u>-</u>	<u>71.2</u>	<u>21.0</u>	<u>499</u>	<u>0</u>	<u>25</u>	<u>0</u>
<u>419</u>	<u>2</u>	<u>71.3</u>	<u>20.9</u>	<u>491</u>	<u>0</u>	<u>23</u>	<u>0</u>
<u>430</u>	<u>-</u>	<u>71.4</u>	<u>20.7</u>	<u>449</u>	<u>0</u>	<u>23</u>	<u>0</u>
<u>426</u>	<u>1</u>	<u>71.4</u>	<u>20.7</u>	<u>465</u>	<u>0</u>	<u>28</u>	<u>0</u>
Hall by <u>410</u>	<u>-</u>	<u>70.7</u>	<u>20.9</u>	<u>460</u>	<u>0</u>	<u>27</u>	<u>0</u>
<u>415</u>	<u>-</u>	<u>70.8</u>	<u>20.6</u>	<u>449</u>	<u>0</u>	<u>24</u>	<u>0</u>
<u>408</u>	<u>2</u>	<u>71.8</u>	<u>21.3</u>	<u>460</u>	<u>0</u>	<u>19</u>	<u>0</u>
<u>406</u>	<u>2</u>	<u>74.1</u>	<u>21.7</u>	<u>572</u>	<u>0</u>	<u>26</u>	<u>0</u>
<u>404</u>	<u>1</u>	<u>73.6</u>	<u>20.6</u>	<u>435</u>	<u>0</u>	<u>22</u>	<u>0</u>
<u>401 (Hall)</u>	<u>-</u>	<u>73.0</u>	<u>20.4</u>	<u>460</u>	<u>0</u>	<u>25</u>	<u>0</u>
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 1/17/02

ATC ASSOCIATES, INC.


Page 4 of 5TIME 9:25

INDOOR AIR QUALITY FIELD REPORT

LOCATION M89 DATE 1/17/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
302	—	72.6	20.4	455	0	25	0
301 (Hall)	—	72.1	20.6	460	0	25	0
315 (Gym)	—	70.3	21.1	465	0	25	0
310 (Hall)	—	69.7	21.0	470	0	26	0
324 (Hall)	—	69.3	21.3	455	0	26	0
326	—	70.0	21.4	449	0	28	0
328 (Hall)	—	69.4	21.7	458	0	26	0
319	—	68.3	21.4	454	0	25	0
332 (Hall)	—	68.2	21.8	466	0	26	0
stair H1	—	68.1	22.2	471	0	26	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 1/17/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 5


TIME 9:50

LOCATION M89 DATE 1/17/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
219	—	68.6	22.7	460	0	39	0
232	—	68.3	22.8	468	0	38	0
228	—	69.1	22.8	470	0	40	0
(Hall) 217	—	69.3	23.1	480	0	37	0
226	—	69.7	22.6	469	0	41	0
208	3	70.0	24.3	600	0	44	0
Hall by Elevator	—	70.4	23.0	480	0	37	0
201	—	71.1	22.2	448	0	30	0
202	—	70.1	21.9	445	0	40	0
Hall by Stair #3	—	70.2	21.8	446	0	35	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/17/02