

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

TIME _____

LOCATION PS89MDATE 1/11/2002PROJECT NO. 19125-0297201 Warren Street, NY, NY

Location	Temp. No2	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOCs (ppm)
501	0.0	73.1	29.7	488	1	11	0.0
502	0.0	75.8	26.5	480	1	15	0.0
504	0.0	92.0	21.4	540	1	17	0.0
506	0.0	77.3	19.5	470	1	18	0.0
517	0.0	84.7	20.5	489	1	13	0.0
519	0.0	74.1	21.0	462	1	14	0.0
532	0.0	75.3	20.8	455	1	15	0.0
528	0.0	72.0	21.3	463	1	15	0.0
526	0.0	75.5	21.6	460	1	14	0.0
512	0.0	73.3	22.4	490	1	14	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 1/11/2002

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

TIME _____

LOCATION PS89M DATE 1/11/2002 PROJECT NO. 19125-0297
201 Warren Street, NY, NY

Location	Ozone <u>NO2</u>	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
510	0.0	83.1	21.9	484	1	17	0.0
508	0.0	74.8	22.5	490	1	13	0.0
Hellway by Elvets	0.0	74.4	22.2	483	1	14	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 1/11/02

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21INC100_014660008

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8

TIME _____

LOCATION PS89M DATE 1/11/2002 PROJECT NO. 19125-0297
201 Warren Street, NY, NY

Location	CO2 NO2	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
401	0.0	71.3	23.1	466	1	7	0.0
402	0.0	70.3	22.7	475	1	8	0.0
404	0.0	71.3	23.2	490	2	8	0.0
406	0.0	71.4	23.2	462	1	7	0.0
Hallway 408	0.0	70.4	22.7	467	1	9	0.0
408	0.0	70.9	22.6	461	2	8	0.0
426	0.0	71.0	21.3	461	1	8	0.0
428	0.0	69.7	21.5	449	1	10	0.0
430	0.0	68.9	22.2	458	2	7	0.0
432	0.0	71.9	22.0	459	1	7	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

1/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8

TIME _____

LOCATION PS89M

DATE 1/11/2002

PROJECT NO. 19125-0297

201 Warren Street, NY, NY

Location	O₃ NO ₂	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m ³)	TVOCs (ppm)
319	0.0	68.5	22.6	495	1	8	0.0
332	0.0	68.6	23.3	473	2	7	0.0
330	0.0	68.1	23.2	449	1	8	0.0
328	0.0	69.1	23.0	440	1	7	0.0
326	0.0	68.4	23.0	460	1	7	0.0
Gym 315	0.0	69.3	23.3	478	1	9	0.0
Hallway 320	0.0	67.4	22.9	449	2	7	0.0
316	0.0	68.3	23.8	468	1	7	0.0
312	0.0	68.6	23.3	446	1	7	0.0
310	0.0	68.7	23.4	416	1	8	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

1/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8

TIME _____

LOCATION PS 89M DATE 1/11/2002 PROJECT NO. 19125-0297
201 Warren Street, NY, NY

Location	Temp. No ₂	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m ³)	TVOCs (ppm)
308	0.0	69.2	23.4	465	1	7	0.0
306	0.0	71.2	23.3	481	1	7	0.0
304	0.0	70.2	23.0	448	1	8	0.0
302	0.0	69.7	23.0	453	1	8	0.0
301	0.0	73.4	23.7	494	1	7	0.0
Hallway Elevator	0.0	71.9	22.6	461	1	7	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 1/11/02

ATC ASSOCIATES, INC.

Page 6 of 8

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89MDATE 1/11/2002PROJECT NO. 19125-0297201 Warren Street, NY, NY

Location	Ozone NO ₂	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m ³)	TVOCs (ppm)
201	0.0	71.3	23.3	465	1	7	0.0
202	0.0	69.8	23.4	458	2	9	0.0
204	0.0	70.2	23.5	446	2	8	0.0
Hallway by Elevator	0.0	70.8	23.7	450	1	8	0.0
Auditorium	0.0	70.5	23.5	455	1	7	0.0
G. office 208	0.0	72.5	23.2	495	1	7	0.0
226	0.0	71.1	23.5	483	2	8	0.0
228	0.0	71.6	23.9	452	2	7	0.0
230	0.0	71.2	24.6	474	2	7	0.0
232	0.0	69.4	24.9	461	2	9	0.0
Guideline levels ASHRAE/NIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 1/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8


TIME _____

LOCATION PS 89M DATE 1/11/2002 PROJECT NO. 19125-0297
201 Warren Street, NY, NY

Location	Ozone NO ₂	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m ³)	TVOCs (ppm)
219	0.0	70.0	23.2	458	2	8	0.0
Halberty 230	0.0	69.5	22.3	480	2	8	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 1/11/02

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_014660013

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

TIME _____

LOCATION PS89M

DATE 1/11/2002 PROJECT NO. 19125-0297

201 Warren Street, NY, NY

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
134		70.9	22.2	505	1	6	0.0
132		70.5	22.3	462	1	6	0.0
126		69.7	22.1	460	1	7	0.0
127		69.3	22.2	458	2	7	0.0
Cafeteria		69.1	22.1	451	2	6	0.0
Kitchen		69.7	22.3	462	1	6	0.0
Hellby by Elvaz		70.6	21.6	450	1	7	0.0
Warren st. Lobby		71.4	21.5	458	1	8	0.0
Chambers st. Lobby		71.3	22.0	450	1	8	0.0
Outdoors		56.5	18.8	448	3	36	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 1/11/02