



104 East 25th Street
 New York, New York 10010
 www.atc-enviro.com
 212.353.8280
 Fax 212.353.8306

December 12, 2001

Mr. Bernard P. Orlan
 Director, Environmental Health & Safety
 New York City Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Re: Settled dust bulk sampling for asbestos at P.S. 89M

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Yiannis Efstathiou (NYC-DEP asbestos investigator #82244 & NYS-DOL asbestos inspector certificate #AH 96-10905) visited P.S. 89M located at 201 Warren Street, New York, NY 10282 on December 11th, 2001. The purpose of the site visit was to perform settled dust bulk sampling to be analyzed for asbestos content from unitvent filters and from the floor area behind the unitvents in locations indicated to ATC by Mr. Alex Lempert director of NYC-SCA Industrial & Environmental Hygiene Division.

A total of six (6) settled dust bulk samples were collected from locations indicated to ATC by a NYC-SCA representative on site. All collected settled dust bulk samples were analyzed utilizing Polarized Light Microscopy (PLM).

The purposed of the dust bulk sampling is to determine if settled dust on the unitvent filters and on the floor area behind the univents contains asbestos.

Analytical results indicated that two (2) collected settled dust bulk samples contain traces of asbestos fibers. All other four (4) collected settled dust bulk samples were found to contain no asbestos fibers.

The provided settled dust bulk sample laboratory results are representative of the materials collected during ATC's site visit only. These laboratory results should not be used to represent "similar" materials collected during other time periods.

Attached please find the following:

- Settled dust bulk sample chain of custody and laboratory results
- Laboratory and personnel certificates



104 East 25th Street
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

If you have any questions or require additional information regarding this limited asbestos dust sampling, please do not hesitate to contact me at (212) 353-8280 extension #261.

Sincerely,

A handwritten signature in black ink, appearing to read 'Andreas C. Andreou', is written over a faint, larger version of the same signature.

Andreas C. Andreou
Senior Project Manager

Mr. Robert Schick, P.E.
Page 2 of 2
January 26, 2004

cc: Ms. Maribeth McCormick – Orange and Rockland Utilities
Mr. Gary Litwin - NYSDOH (2 copies)
Mr. Charles E. Sullivan, Jr. – NYSDEC
Mr. Marc Moran - NYSDEC Region III
Thomas Knight, Esq. - Presidential Life Insurance
David S. Yudelson, Esq. - Sive, Paget & Reisel, P.C.
Mr. Jerome Johnson - Presidential Life Insurance
Mr. John Conrad - Conrad Geoscience
Ms. Catherine M. Quinn, P.E. - Rockland County Health Department
File: ORAN2-04301-700

PRES LIFE 003780