

ATC Environmental, Inc.
104 East 25th Street
New York, New York 10010

ATC Associates Inc.
104 East 25th Street
New York, NY 10010

Approved N.Y. State ELAP #10879
ACCREDITED NVLAP Lab Code # 1187
Report Date: 09/29/01

ASBESTOS FIBER ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY (TEM)

With Fiber Identification by Selected-Area Electron Diffraction (SAED) and Energy-Dispersive X-RAY Spectroscopy (EDS)
Method: AHERA Final Rule, EPA Federal Register (40 CFR, Part 763), Vol. 52, No. 210, October 30, 1987

Sample Identification

Analysis Parameters

Project/Site: 40 Rector Street, NY, NY
Floors 6, 7, 3, 4, 11, 2, 1/Lobby
Date Received: 09/29/01

TEM Sample No.: 5579 - 59745

Grid Openings Analyzed: 6

Project Sample No.: T22

Average Grid Opening: 106.00 um

Air Volume: 1290 liters

Total Area Analyzed: 0.0674 mm2

Filter Type: MCE 25 mm diam., Pore Size: 0.45 um
Effective Area: 385 mm2

Analytical Sensitivity: 14.8 s/mm2
0.0044 s/cc

FIBROUS PARTICULATES ANALYZED

Number Observed

CONCENTRATION

	<u>Number Observed</u>			<u>CONCENTRATION</u>					
	Single Fibers	Bundles	Clusters	Matrix Struct.	Total Struct.	Total Struct. >=5um	Filter Struct/mm2	Air Struct/cc	Air ngm/m3
Chrysotile Asbestos	0	0	0	0	0	0	0.0	0.0000	0
Amphibole Asbestos	0	0	0	0	0	0	0.0	0.0000	0
Ambiguous	0	0	0	0	0	0	0.0	0.0000	0
Total asbestos (includes ambiguous structures)					0	0	0.0	0.0000	0
Non-Asbestos	0	0	0	0	0	0	0.0	0.0000	N/A
No Identification	0	0	0	0	0	0	0.0	0.0000	N/A
Totals (All Structures)					0	0	0.0	0.0000	N/A

The estimated uncertainty of this analysis is 1 standard deviation.

Non-asbestos fiber i.d. (EDS/SAED): None detected
Amphibole Asbestos Type: None detected

The Analysis was carried out in accordance with the approved TEM method.
This laboratory is in compliance with the quality specified for the method.

Analyzed by:

Report Reviewed by:

Marek Peysakhov

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy