



MORETRENCH AMERICAN CORPORATION

www.moretrench.com

January 29, 2002

Serial Letter 01-4906-45

VIA FACSIMILE (3 wfc)
(212) 640-9207

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
52 Chambers Street
New York, NY 10007

Total # of Pages: 7

**RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses**

Dear Brian:

Attached find the results of the analysis of the water samples taken from the WTC site on January 21, 2002. MTBE levels for the sump discharge (South Projection) and dewatering discharge (Main Discharge) are 88 ppb and 9 ppb respectively.

We are also forwarding a copy of the table which tracks MTBE concentration for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe
President

cc: Billy Klingler, MTA

MORETRENCH SERVICES.....

- BORED PILES & SHAFTS
- CUTOFF/CONTAINMENT WALLS
- DEWATERING
- GROUND FREEZING
- GROUNDWATER REMEDIATION
- INDUSTRIAL INFRASTRUCTURE
- LANDFILL GAS/LEACHATE SYSTEMS
- SOIL MODIFICATION/SOIL STABILIZATION

CONFIDENTIAL,

CITY_21MC100_003487168

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008