NYC 9/11 Public Portal Document

SciLab Job #: **101101047**
Client Name: HP ENVIRONMENTAL, INC.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
35802; WTC - Bldg. A; World Financial Center

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns) 0.5-5.0	>5.0	Total	Structure Density (struc/sq. mm.) >5.0	Total	Structure Concentration (struc/cc air) >5.0	Total	Type of Asbestos
01	BLDG A-0928-A1		390	.100	0.0098	8.0	0.0	8.0	<10	79.8	<0.0098	0.0787	chrysotile
02	BLDG A-0928-A2		380	.100	0.0101	17.0	2.0	19.0	19.9	189.4	0.0202	0.1919	chrysotile
03	BLDG A-0928-A3		390	.100	0.0098	13.0	3.0	16.0	29.9	159.5	0.0295	0.1575	chrysotile
04 blank	BLDG A-0928-FB1			.100	1.0000	0.0	0.0	0.0	<10	<10			NSD
05 blank	BLDG A-0928-FB2			.100	1.0000	0.0	0.0	0.0	<10	<10			NSD

06.002492

* concentration represented by the detection of 1 structure
** not analyzed
NSD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: Brian Keith Date: 10/1/01

NVLAP#- 101904-0

OCT-02-2001 00:44 SCIENTECH LABS

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_00341649

NYC-WTC_000174998