NYC 9/11 Public Portal Document

JUN-12-2002 WED 03:38 PM PITNEYHARDINKIPPSZUCH FAX NO. 212 682 6328 P. 20

Polarized Light Microscopy (PLM) Results, EPA/600/R-93/116 (NYS ELAP 198.1) Point Count Method
RJ Lee Group Project No. LSH204785

Analyst: WHP

Analysis Report for Gash Emergency Samples collected 06/05/02

Sample ID	RJ Lee Group Sample ID	Building/location (desc.)	Non-Asbestos Components		Asbestos Content	Comments
18-A (Bag) 130 Liberty Street	3030867	Floor 18 Grid A	Non-fibrous matr'l Fibrous Glass Cellulose	72.75 % 24.00 % 3.00 %	Chrysotile 0.25%	Gray Fibrous Debris
19-F (Bag) 130 Liberty Street	3030866	Floor 19 Grid F	Non-fibrous matr'l Fibrous Glass Cellulose	62.00 % 26.50 % 11.25 %	Amosite < 0.25%	Gray Fibrous Debris
20-F (Bag) 130 Liberty Street	3030875	Floor 20 Grid F	Non-fibrous matr'l Fibrous Glass Cellulose	67.25 % 21.25 % 11.50 %	None detected	Gray Fibrous Debris
21-D (Bag) 130 Liberty Street	3030872	Floor 21 Grid D	Non-fibrous matr'l Cellulose Fibrous Glass	82.25 % 12.25 % 5.50 %	None detected	White Fibrous Debris
22-F (Bag) 130 Liberty Street	3030881	Floor 22 Grid F	Non-fibrous matr'l Fibrous Glass Cellulose	65.25 % 22.75 % 12.00 %	None detected	Gray Fibrous Debris
23-A (Bag) 130 Liberty Street	3030887	Floor 23 Grid A	Non-fibrous matr'l Fibrous Glass Cellulose	78.00 % 15.50 % 6.50 %	None detected	Gray Fibrous Debris
24-H (Bag) 130 Liberty Street	3030886	Floor 24 Grid H	Non-fibrous matr'l Fibrous Glass Cellulose	69.25 % 28.00 % 2.75 %	None detected	Gray Fibrous Debris

RJ LeeGroup, Inc.
350 Hochberg Road
Monroeville, PA 15146

CITY_21MC100_014594526

NYC-WTC_000175003