

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-21-02
CLIENT: NYC BOE
PROJECT ADDRESS: PS 126 M & M 893
Catherine Street, NY, NY
PROJECT NO: 41617-0901
SAMPLED BY: H. Antonyan
SAMPLE DATE: 08-21-02
DATE RECEIVED: 08-21-02
DATE ANALYZED: 08-21-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
		126 M		
01	9948	1st Floor Lobby - Floor	<9.0	9.0
02	9948	Cafeteria Floor	<9.0	9.0
03	9948	Auditorium Floor	<9.0	9.0
04	9948	Classroom 123 Floor	<9.0	9.0
05	9948	Classroom 125 Window Sill	<4.0	4.0
06	9948	Classroom 203 Floor	<9.0	9.0
07	9948	Classroom 237 Floor	<9.0	9.0
08	9948	1st Floor Hallway Floor	<9.0	9.0
09	9948	2nd Floor Hallway Floor	<9.0	9.0
10	9948	3rd Floor Hallway Floor	<9.0	9.0
11	9948	Classroom 319 Floor	<9.0	9.0

CONFIDENTIAL,

CITY_21MC100_003430859

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

12	9948	Classrom 325 Window Sill	<4.0	4.0
		M 893		
13	9948	Classroom 443 Floor	<9.0	9.0
14	9948	Classroom 429 Window Sill	<4.0	4.0
15	9948	4th Floor Hallway Floor	<9.0	9.0
16	9948	Blank	<9.0 µg	9.0 µg
17	9948	Blank	<9.0 µg	9.0 µg

NOTE 1:**THE REPORTING LIMIT (RL) IS 18.0 µg****NOTE 2:**HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².**NOTE 3:**

Blank units are in µg

CERTIFICATION AND SIGNATURES**ANALYSIS PERFORMED BY:** AW**REPORT PREPARED BY:** mu

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: mu**LABORATORY DIRECTOR:** mu

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CONFIDENTIAL,

CITY_21MC100_003430860

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008