

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**

---

**REPORT DATE:** 08-22-02  
**CLIENT:** NYC BOE  
**PROJECT ADDRESS:** 100 Hester Street, NY, NY  
**PROJECT NO:** 41617-0904  
**SAMPLED BY:** H. Antonyan  
**SAMPLE DATE:** 08-22-02  
**DATE RECEIVED:** 08-22-02  
**DATE ANALYZED:** 08-22-02  
**SAMPLE MEDIA:** Dust Wipe Sample  
**ANALYSIS REQUIRED:** Method EPA 3050/7420

---

---

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION       | LEAD CONCENTRATION ( $\mu\text{g}/\text{ft}^2$ ) | DETECTION LIMIT ( $\mu\text{g}/\text{ft}^2$ ) |
|-----------|-----------|--------------------------|--------------------------------------------------|-----------------------------------------------|
| 01        | 9950      | Rm 433 Window Sill       | <5.4                                             | 5.4                                           |
| 02        | 9950      | Hallway by Rm 435 Floor  | <9.0                                             | 9.0                                           |
| 03        | 9950      | Rm 440 Floor             | 9.9                                              | 9.0                                           |
| 04        | 9950      | Hallway by 318 Floor     | <9.0                                             | 9.0                                           |
| 05        | 9950      | Rm 324 Window Sill       | <5.4                                             | 5.4                                           |
| 06        | 9950      | Rm 308 Window Sill       | <9.0                                             | 9.0                                           |
| 07        | 9950      | Hallway by Rm 237 Floor  | <9.0                                             | 9.0                                           |
| 08        | 9950      | Rm 242 Window Sill       | <5.4                                             | 5.4                                           |
| 09        | 9950      | Rm 248A Floor            | <9.0                                             | 9.0                                           |
| 10        | 9950      | Hallway by Rm 140 Floor  | <9.0                                             | 9.0                                           |
| 11        | 9950      | Rm 129 Floor             | <9.0                                             | 9.0                                           |
| 12        | 9950      | Teachers Cafeteria Floor | <9.0                                             | 9.0                                           |
| 13        | 9950      | South Cafeteria Floor    | <9.0                                             | 9.0                                           |

CONFIDENTIAL,

CITY\_21MC100\_003422003

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**

|    |      |                   |         |        |
|----|------|-------------------|---------|--------|
| 14 | 9950 | Main Lobby Floor  | <9.0    | 9.0    |
| 15 | 9950 | Auditorium Floor  | <9.0    | 9.0    |
| 16 | 9950 | Hallway by Rm C40 | <9.0    | 9.0    |
| 17 | 9950 | GYM               | <9.0    | 9.0    |
| 18 | 9950 | Blank             | <9.0 µg | 9.0 µg |
| 19 | 9950 | Blank             | <9.0 µg | 9.0 µg |

**NOTE 1:****THE REPORTING LIMIT (RL) IS 18.0 µg****NOTE 2:**HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft<sup>2</sup>, Window sills 250 µg/ft<sup>2</sup>, Window wells 400 µg/ft<sup>2</sup>, Exterior surfaces 800 µg/ft<sup>2</sup>.**NOTE 3:**

Blank units are in µg

---

---

**CERTIFICATION AND SIGNATURES****ANALYSIS PERFORMED BY:** MW**REPORT PREPARED BY:** J. Harte

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** WST**LABORATORY DIRECTOR:** M.L.

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CONFIDENTIAL,

CITY\_21MC100\_003422004

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008