

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 09-10-02

CLIENT: NYC BOE

PROJECT ADDRESS: 411 Pearl Street

PROJECT NO: 41617-0908
SAMPLED BY: M. Nakhumovich

SAMPLE DATE: 09-09-02
DATE RECEIVED: 09-09-02
DATE ANALYZED: 09-09-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9984	1st Floor Lobby Floor	<9.0	9.0
02	9984	Cafeteria Floor	<9.0	9.0
03	9984	Auditorium Floor	16.5	9.0
04	9984	Classroom 203 Floor	<9.0	9.0
05	9984	Classroom 207 Window Sill	9.4	7.0
06	9984	5th Floor Hallway by Rm 506 Floor	<9.0	9.0
07	9984	4th Floor Hallway by Rm 411 Floor	11.0	9.0
08	9984	3rd If Hallway by Rm 352 Floor	<9.0	9.0
09	9984	2nd Floor Hallway by Rm 203 Floor	<9.0	9.0
10	9984	1st Floor Hallway by Rm 159 Floor	<9.0	9.0
11	9984	Basement Hallway by Rm B59 Floor	11.7	9.0
12	9984	Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CONFIDENTIAL,

CITY_21MC100_003422304

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: HCV

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CONFIDENTIAL,

CITY_21MC100_003422305

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008