NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-22-02

CLIENT: NYC BOE

PROJECT ADDRESS: 100 Hester Street, NY, NY

PROJECT NO: 41617-0904

SAMPLED BY: H. Antonyan

SAMPLE DATE: 08-22-02
DATE RECEIVED: 08-22-02
DATE ANALYZED: 08-22-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	9950	Rm 433 Window Sill	<5.4	5.4
02	9950	Hallway by Rm 435 Floor	<9.0	9.0
03	9950	Rm 440 Floor	9.9	9.0
04	9950	Hallway by 318 Floor	<9.0	9.0
05	9950	Rm 324 Window Sill	<5.4	5.4
06	9950	Rm 308 Window Sill	<9.0	9.0
07	9950	Hallway by Rm 237 Floor	<9.0	9.0
08	9950	Rm 242 Window Sill	<5.4	5.4
09	9950	Rm 248A Floor	<9.0	9.0
10	9950	Hallway by Rm 140 Floor	<9.0	9.0
11	9950	Rm 129 Floor	<9.0	9.0
12	9950	Teachers Cafeteria Floor	<9.0	9.0
13	9950	South Cafeteria Floor	<9.0	9.0

CONFIDENTIAL, CITY_21MC100_003422522

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000175379

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

14	9950	Main Lobby Floor	<9.0	9.0
15	9950	Auditorium Floor	<9.0	9.0
16	9950	Hallway by Rm C40	<9.0	9.0
17	9950	GYM	<9.0	9.0
18	9950	Blank	<9.0 µg	9.0 µg
19	9950	Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: MW

REPORT PREPARED BY: [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [signature]

LABORATORY DIRECTOR: [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).