



104 East 25th St 10th Fl
New York New York 10010
www.atc-enviro.com
212 353 8280
Fax 212 353 8306

August 23 2002

N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Attn Mr Bernard Orlan

Re Report of TEM Analysis

Dear Mr Orlan

Following are the results of transmission electron microscopy (TEM) analysis of air samples from our Group No 8739

Project Name P S 131M 100 Hester Street NY NY
Location Entire School Inside and Out
Samples received 08/22/02

These results will confirm and document the data transmitted today to Mr Yiannis Efsthathiou Project Manager of our office The analyses were performed in strict conformance with the methodology of the AHERA Final Rule (40 CFR Part 763 Appendix A to Subpart E October 30 1987) for clearance of abatement sites

The results of the sample analyses are as indicated on the attached document

Copies of the bench sheets are also included as stipulated by AHERA Results reported as Struct/cc are a function of air volume collected in the field and are as such not verifiable by this laboratory This report may be reproduced only in its entirety and not without prior permission of this laboratory If post abatement inside samples pass the response action may be considered to have been completed

We are pleased to note that our TEM lab has received full accreditation from NVLAP as is currently required for recognized analysis of TEM air samples for AHERA projects and also approval under the NY State DOH ELAP program These analyses were performed by ATC d/b/a ATC Associates Inc Please contact me regarding any questions relating to these materials

Very truly yours

Michael A Gorycki Ph D
Director of Electron Microscopy

CONFIDENTIAL,

CITY_21MC100_003431134

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008