NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
Playground, Roof 5th&2nd Floor,1st Floor Hallwa

Received: 1/20/02 4:00:00 AM

ATC Group #: 6386

Analysis Date: 1/20/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5	Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 6386 -1	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
02 6386 -2	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
03 6386 -3	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
04 6386 -4	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
05 6386 -5	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
06 6386 -6	1875.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

ROMAN PEYSAKHOV
Analyzed by: RRy

MICHAEL A. GORYCKI, Ph.D.
Approved by: Michael A Gorycki

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879