

AIC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-28-02
DATE RECEIVED: 07-29-02
DATE ANALYZED: 07-29-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	20725	Rm 1010 Floor 4' South of Center Wall Column	<9.0	9.0
LW-02	20725	Rm 1010 Work Table Top 7' South of Center Wall Column	<9.0	9.0
LW-03	20725	Rm 1025 Floor 3' of West Entrance. Off Corridor	<9.0	9.0
LW-04	20725	Rm 1025 Student Desk Top Window Row Front	<9.0	9.0
LW-05	20725	Rm 1033 Floor South Side of NW Column	<9.0	9.0
LW-06	20725	Rm 1033 Drafting File Cabinet Top (NW Corner Cabinet)	<9.0	9.0
FBL-1	20725	Field Blank	<9.0 μg	9.0 μg
FBL-2	20725	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_003433831

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008