NYC 9/11 Public Portal Document

New York Lab
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: U. S. EPA
HQ Financial Services Division
1200 Pennsylvania Ave. NW Maildrop 2734R
Washington, DC 20460

Fax: Phone:

Project: **USPHS Mission #12:Residential Sampling New York City-Bldg. 2**

Customer ID: USEPA30
Customer PO: 2W-1104-NNLX
Received: 11/14/01 8:32 PM

EMSL Order: 030108037
EMSL Project ID:

Analysis Date: 11/15/2001

Asbestos Analysis of Bulk Materials by PLM via the NY State ELAP 198.1 Method

				Non-Asbestos			Asbestos
Sample	Location	Appearance	Treatment	% Fibrous		% Non-Fibrous	% Type
[R]SA-O-2 *030108037-0001*	Outdoors	Gray/White Fibrous Heterogeneous	Dissolved Teased	28.00% Glass 32.00% Cellulose		40.00% Non-fibrous (other)	<1% Chrysotile
[R]VA-C-2 *030108037-0002*	Common Area	Gray Fibrous Heterogeneous	Dissolved Teased	20.00% Synthetic 27.00% Glass 30.00% Cellulose		23.00% Non-fibrous (other)	None Detected
[R]VA-R1-2 *030108037-0003*	Residence 1	Gray Fibrous Heterogeneous	Dissolved Teased	20.00% Synthetic 25.00% Glass 30.00% Cellulose		25.00% Non-fibrous (other)	None Detected
[R]VA-R2-2 *030108037-0004*	Residence 2	Gray Fibrous Heterogeneous	Dissolved Teased	20.00% Hair 20.00% Glass 30.00% Cellulose		30.00% Non-fibrous (other)	None Detected
[R]VA-R3-2 *030108037-0005*	Residence 3	Gray/White Fibrous Heterogeneous	Dissolved Teased	30.00% Glass 22.00% Cellulose		48.00% Non-fibrous (other)	<1% Chrysotile

Ram Yallabandi
Analyst

Laboratory Manager
or other approved signatory

PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Negative PLM results cannot be guaranteed. Samples reported as <1% or none detected should be tested with TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government.
Analysis performed by EMSL Manhattan (NVLAP #101048-9), NY ELAP 11508

PLM Point Count-1



CONFIDENTIAL, CITY_21MC100_003423508

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176104