

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:



Attn: U.S. EPA - Residential
HQ Financial Services Division
1200 Pennsylvania Ave. NW Maildrop 2734R
Washington, DC 20460

Fax: Phone:

Project: USPHS Mission #12: Residential Sampling New York
City / Bldg /136 Beekman

Customer ID: USEPA44
Customer PO: 2W-1103-NNLX
Received: 11/24/01 7:21 PM

EMSL Order: 030108608

EMSL Project ID:

Analysis Date: 11/26/2001

Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Treatment	% Fibrous	Non-Asbestos		Asbestos
					% Non-Fibrous		% Type
(R)VA-C-17 030108608-0001	COMMON AREA	Gray Fibrous Heterogeneous	Teased Dissolved	5% Synthetic 2% Min. Wool 40% Cellulose	53% Non-fibrous (other)		None Detected
(R)VA-R1-17 030108608-0002	RESIDENCE 1	Gray Fibrous Heterogeneous	Teased Dissolved	20% Synthetic 40% Cellulose	40% Non-fibrous (other)		None Detected
(R)VA-R2-17 030108608-0003	RESIDENCE 2	Gray Fibrous Heterogeneous	Teased Dissolved	30% Synthetic 5% Cellulose	65% Non-fibrous (other)		None Detected

Analyst(s)

Dan Osborne (3)

Laboratory Manager
or other approved signatory

PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Negative PLM results cannot be guaranteed. Samples reported as <1% or none detected should be tested with TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government.

Analysis performed by EMSL Manhattan (NVLAP #101048-9), NY ELAP 11506



CONFIDENTIAL,

CITY_21MC100_003434142

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176117