NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentrati (S/mm²)	Asbestos Concentrati (S/cc)
522	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004
523	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004
524	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004
525	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004
526	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004
527	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.004

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

1

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CONFIDENTIAL INSURANCE INFORMATION_CITY_21MC100_010800184

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176194

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
528	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
529	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
530	1330.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
531	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
532	1420.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
533	1420.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043

Earl Tracey
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT PH-0249

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800185
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176195

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
534	1420.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
535	1430.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
536	1440.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
537	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
538	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
539	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800186
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
540	1550.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
541	1560.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
542	1620.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
543	1620.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
544	1620.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
545	1690.00	None Detected			0	0.0508	0.0045	<19.69	<0.0045

Earl Tracey
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2330, CT PH-0574

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800187

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176197

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
546	1660.00	None Detected			0	0.0508	0.0046	<19.69	<0.0046
547	1550.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
548	1550.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
549	1550.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
550	1560.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
551	1550.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY LLAP 11469, CA LLAP 2339, CT PH 0249

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800188

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
552	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
553	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
554	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
555	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
556	1310.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
557	1230.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

6

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800189
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
558	1230.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
559	1230.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
560	1630.00	None Detected			0	0.0508	0.0046	<19.69	<0.0046
561	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
562	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
563	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0243

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800190

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176200

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
564	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
565	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
566	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
567	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
568	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
569	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800191

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176201

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
570	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
571	1290.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
572	0.00	None Detected			0	0.0635		<15.75	
573	0.00	None Detected			0	0.0635		<15.75	
574	0.00	None Detected			0	0.0635		<15.75	

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

9

Accredited for NVLAP PLM/TEM #101048-10, NYLLAP 11469, CA ELAP 2339, CT PH-0208

CONFIDENTIAL INSURANCE INFORMATION, CITY_21MC100_010800192

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000176202