EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
207	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
208	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
209	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
210	1390.00	None Detected			0	0.0635	0.0044	<15.75	<0.0044
211	1370.00	None Detected			0	0.0635	0.0044	<15.75	<0.0044
212	1360.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045

Daniel Clarke
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

1

Accredited for NVLAP PLM/TEM #101048-10, NY PLAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_012545243

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
213	1360.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
214	1360.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
215	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
216	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
217	1600.00	None Detected			0	0.0635	0.0038	<15.75	<0.0038
218	1600.00	None Detected			0	0.0635	0.0038	<15.75	<0.0038

Daniel Clarke
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
219	1600.00	None Detected			0	0.0635	0.0038	<15.75	<0.0038
220	1590.00	None Detected			0	0.0635	0.0038	<15.75	<0.0038
221	1590.00	None Detected			0	0.0508	0.0048	<19.69	<0.0048
222	1530.00	None Detected			0	0.0508	0.0050	<19.69	<0.0050
223	1580.00	Chrysotile Anthophyllite	0 1	1 0	0	0.0508	0.0048	39.37	0.0096
224	1580.00	None Detected			0	0.0508	0.0048	<19.69	<0.0048

Daniel Clarke
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
225	1580.00	None Detected			0	0.0508	0.0048	<19.69	<0.0048
226	1600.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
227	1600.00	None Detected			2	0.0508	0.0047	<19.69	<0.0047
228	1600.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
229	1600.00	None Detected			0	0.0508	0.0047	<19.69	<0.0047
230	1600.00	None Detected			1	0.0508	0.0047	<19.69	<0.0047

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0240

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
231	0.00	Not Submitted			0	0.0000			
232	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
233	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
234	1450.00	None Detected			3	0.0635	0.0042	<15.75	<0.0042
235	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
236	1450.00	None Detected			2	0.0635	0.0042	<15.75	<0.0042

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY FLAP 11469, CA ELAP 2339, CT PH-0249

NYC-WTC_000176210

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
237	1500.00	Chrysotile	0	1	1	0.0635	0.0040	15.75	0.0040
238	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
239	1500.00	None Detected			1	0.0635	0.0040	<15.75	<0.0040
240	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
241	1490.00	None Detected			0	0.0635	0.0041	<15.75	<0.0041
242	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM: TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT PH-0249

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
247	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
248	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
249	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
250	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
251	1300.00	Not Submitted			0	0.0000			
252	1200.00	Chrysotile	1	0	1	0.0635	0.0051	15.75	0.0051

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH 0249

CITY_21MC100_012545249

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
253	1200.00	None Detected			0	0.0762	0.0042	<13.12	<0.0042
254	1200.00	None Detected			0	0.0762	0.0042	<13.12	<0.0042
255	1200.00	None Detected			0	0.0762	0.0042	<13.12	<0.0042
256	1200.00	None Detected			0	0.0762	0.0042	<13.12	<0.0042
257	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
258	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046

Daniel Clarke
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_012545250

NYC-WTC_000176213

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
259	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
260	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
261	0.00	Not Submitted			0	0.0000			
262	0.00	None Detected			0	0.0762		<13.12	
263	0.00	None Detected			0	0.0635		<15.75	
264	0.00	None Detected			0	0.0635		<15.75	

Daniel Clarke
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101046-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

9