

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 3/23/02 8:00:00 PM

ATC Group #: 7186

Analysis Date: 3/24/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity	Asbestos Concentration		Notes
					0.5µ-5	5µ	(S/cc)	(S/mm ²)	(S/cc)	
01 7186 -1	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
02 7186 -2	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
03 7186 -3	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
04 7186 -4	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
05 7186 -5	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
06 7186 -6	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
07 7186 -7	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 2

CONFIDENTIAL,

CITY_21MC100_003470512

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 3/23/02 8:00:00 PM
 ATC Group #: 7186
 Analysis Date: 3/24/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
08 7186 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
09 7186 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 7186 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
11 7186 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 7186 -12	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7186 -13	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7186 -14	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7186 -15	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7186 -16	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879