

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/2/02 8:00:00 PM
ATC Group #: 7606
Analysis Date: 5/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 7606 -1	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
02 7606 -2	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
03 7606 -3	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
04 7606 -4	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 7606 -5	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
06 7606 -6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 7606 -7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Page 1 of 2

CONFIDENTIAL,

CITY_21MC100_003471419

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/2/02 8:00:00 PM
ATC Group #: 7606
Analysis Date: 5/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
08 7606 -8	1840.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
09 7606 -9	1840.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
10 7606 -10	1840.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
11 7606 -11	1840.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
12 7606 -12	1814.50	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
13 7606 -13	1805.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
14 7606 -14	1805.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
15 7606 -15	1805.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
16 7606 -16	1805.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 2 of 2

CONFIDENTIAL,

CITY_21MC100_003471420

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008