

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**

---

**REPORT DATE:** 04-06-02  
**CLIENT:** NYC BOE  
**PROJECT ADDRESS:** PS89M/201 Warren Street  
NY, NY 10282  
**PROJECT NO:** 41617-0562  
**SAMPLED BY:** H. Antonyan  
**SAMPLE DATE:** 04-05-02  
**DATE RECEIVED:** 04-05-02  
**DATE ANALYZED:** 04-05-02  
**SAMPLE MEDIA:** Dust Wipe Sample  
**ANALYSIS REQUIRED:** Method EPA 3050/7420

---

---

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION                              | LEAD CONCENTRATION ( $\mu\text{g}/\text{ft}^2$ ) | DETECTION LIMIT ( $\mu\text{g}/\text{ft}^2$ ) |
|-----------|-----------|-------------------------------------------------|--------------------------------------------------|-----------------------------------------------|
| 01        | 9752      | Classroom #401 Window Sill                      | <7.2                                             | 7.2                                           |
| 02        | 9752      | Classroom #401 Floor                            | <9.0                                             | 9.0                                           |
| 03        | 9752      | Classrom #401 Floor                             | <9.0                                             | 9.0                                           |
| 04        | 9752      | 4th Floor Hallway by Entrance of C.R.#401 Floor | <9.0                                             | 9.0                                           |
| 05        | 9752      | Blank                                           | <9.0 $\mu\text{g}$                               | 9.0 $\mu\text{g}$                             |

**NOTE 1:**

**THE REPORTING LIMIT (RL) IS 18.0  $\mu\text{g}$**

**NOTE 2:**

HUD Guidelines for final clearance dust wipe samples: Floor 40  $\mu\text{g}/\text{ft}^2$ , Window sills 250  $\mu\text{g}/\text{ft}^2$ , Window wells 400  $\mu\text{g}/\text{ft}^2$ , Exterior surfaces 800  $\mu\text{g}/\text{ft}^2$ .

**NOTE 3:**

Blank units are in  $\mu\text{g}$

CONFIDENTIAL,

CITY\_21MC100\_003471604

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008