

SciLab Job #: 202041002

Client Name: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM 5755 Dust)

35052-0000-00009; New York Law Department; 100 Church Street

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Structure Density on Surface (Str/ sq. cm)	Type of Asbestos
01	GS-3/24/02-VAC-0201 Painted/ South Side Office - Top Of Induction Unit - Room 2-201	100.0	0.100	0	25	<25	535	<535	NSD
02	GS-3/29/02-VAC-2001 Aluminum Foil/ SW Corner (Top Of Ceiling Tile)	100.0	0.100	1	25	25.0	535	535	chrysotile
03**	GS-3/29/02-VAC-BLANK Blank				1				

* structure density represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____ ; Analyzed By:  Date: 4/1/02

Aleksandr Barenholtz

1196

APR-01-2002 15:27

SCIENTIFIC LABS

212 679 9392 P. 02/03