

FEB. 11. 2002 9:45AM IATL

NO. 711 P. 11

IATL International Asbestos
Testing Laboratories

16000 Horizon Way Unit 100 Mt. Laurel, NJ 08054

Telephone: 856-231-9449 Fax: 856-231-9818

CERTIFICATE OF ANALYSIS**Client:** TRC Engineers, Inc.
134 West 29th Street, 11th Flr
New York, NY 10001**Report Date:** 12/31/2001
Project: NYC Law 100 Church St, 12-18-01
Project No.: 834345**TEM AIR SAMPLE ANALYSIS SUMMARY**

<u>Lab No</u>	<u>Client No.</u>	<u>Location</u>	<u>Volume</u>	<u>Result</u>	<u>Asbestos Types</u>
1403445	ASB-1218-4th-A21	Center Of N-Wall	1470 Liters	<11.0 Fibers/mm2 <0.0029 Fibers/cc	None Detected
1403446	ASB-1218-4th-A22	Rm 4-100 SW Corner	1470 Liters	<11.0 Fibers/mm2 <0.0029 Fibers/cc	None Detected
1403447	ASB-1218-4th-A23	Rm 4-109 S. Wall	1450 Liters	<11.0 Fibers/mm2 <0.0029 Fibers/cc	None Detected
1403448	ASB-1218-4th-A24	Near Rm 4-115 S. Wall	1450 Liters	11.0 Fibers/mm2 0.0029 Fibers/cc	Chrysotile
1403449	ASB-1218-4th-A25	Rm 4-141 SE Corner	1430 Liters	<11.0 Fibers/mm2 <0.0030 Fibers/cc	None Detected

Member AIHA Analysts Registry AIHA Lab No. 444 NIST-NVLAP No. 1165 NYS-DOH No. 11021

Methodology: NIOSH 7402


This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP or any agency of the U.S. government.

Analysis Performed By:

Date: DEC 21 2001


Craig A. Ulska, AIHA-AAR 4681

Approved By:


Frank B. Ehrenfeld, III
Laboratory Director

1600

FEB. 11. 2002 9:46AM IATL

NO. 711 P. 12

IATL International Asbestos
Testing Laboratories

16000 Horizon Way Unit 100 Mt. Laurel, NJ 08054

Telephone: 856-231-9449 Fax: 856-231-9818

CERTIFICATE OF ANALYSIS

Client: TRC Engineers, Inc.
134 West 29th Street, 11th Flr
New York, NY 10001

Report Date: 12/31/2001
Project: NYC Law 100 Church St, 12-18-01
Project No.: 834345


TEM AIR SAMPLE ANALYSIS SUMMARY

<u>Lab No</u>	<u>Client No.</u>	<u>Location</u>	<u>Volume</u>	<u>Result</u>	<u>Asbestos Types</u>
1403450	ASB-1218-4th-A26	E Wall Center	1430 Liters	<11.0 Fibers/mm2 <0.0030 Fibers/cc	None Detected
1403451	ASB-1218-4th-A27	NE Corner Near 4-161	1429 Liters	<11.0 Fibers/mm2 <0.0030 Fibers/cc	None Detected
1403452	ASB-1218-4th-A28	N Wall Near 4-176	1428 Liters	11.0 Fibers/mm2 0.0030 Fibers/cc	Chrysotile
1403453	ASB-1218-4th-A29	N Wall Near 4-190	1427 Liters	<11.0 Fibers/mm2 <0.0030 Fibers/cc	None Detected
1403454	ASB-1218-4th-A30	NW Corner Near 4-200	1426 Liters	11.0 Fibers/mm2 0.0030 Fibers/cc	Chrysotile

Member AIHA Analysts Registry AIHA Lab No. 444 NIST-NVLAP No. 1165 NYS-DOH No. 11021


Methodology: NIOSH 7402

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP or any agency of the U.S. government.

Analysis Performed By: 

Date: DEC 21 2001

Craig A. Liska, AIHA-AAR 4881

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

1601

FEB. 11. 2002 9:46AM IATL

NO. 711 P. 13

IATL International Asbestos
Testing Laboratories

16000 Horizon Way Unit 100 Mt. Laurel, NJ 08054
Telephone: 856-231-9449 Fax: 856-231-9818

CERTIFICATE OF ANALYSIS

Client: TRC Engineers, Inc.
134 West 29th Street, 11th Flr
New York, NY 10001

Report Date: 12/31/2001
Project: NYC Law 100 Church St, 12-18-01
Project No.: 834345

TEM AIR SAMPLE ANALYSIS SUMMARY

<u>Lab No</u>	<u>Client No.</u>	<u>Location</u>	<u>Volume</u>	<u>Result</u>	<u>Asbestos Types</u>
1403455	ASB-1218-5th-A31	CL Griffith Cube	1200 Liters	<9.6 Fibers/mm2 <0.0031 Fibers/cc	None Detected
1403456	ASB-1218-5th-A32	Rm 5-115	1200 Liters	<9.6 Fibers/mm2 <0.0031 Fibers/cc	None Detected
1403457	ASB-1218-5th-A33	Rm 5-122	1200 Liters	<9.6 Fibers/mm2 <0.0031 Fibers/cc	None Detected
1403458	ASB-1218-5th-A34	Cafeteria Entrance	1200 Liters	<9.6 Fibers/mm2 <0.0031 Fibers/cc	None Detected
1403459	ASB-1218-5th-A35	Rm 5-131	1200 Liters	<9.6 Fibers/mm2 <0.0031 Fibers/cc	None Detected

Member AIHA Analysts Registry AIHA Lab No. 444 NIST-NVLAP No. 1165 NYS-DOH No. 11021

Methodology: NIOSH 7402


This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP or any agency of the U.S. government.

Analysis Performed By:


Craig A. Uska, AIHA-AAR 4881

Date: DEC 21 2001

Approved By:


Frank E. Ehrenfeld, III
Laboratory Director

1602