NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: **TRC Environmental Consultants**
1430 Broadway, 10th Floor
New York, NY 10018

Fax: (212) 221-7840 Phone: (212) 221-7822
Project: NYCLD/ 100 CHURCH ST/ NYC LAW DEPT./ 2ND FLOOR

Customer ID:	TRCE51
Customer PO:	
Received:	04/11/05 5:51 PM
EMSL Order:	030509613
EMSL Proj:	100 Church Street
Analysis Date:	4/12/2005
Report Date:	4/12/2005

Asbestos Analysis of Wipe Samples Using Method ASTM 6480-99

SAMPLE ID	AREA SAMPLED (cm^2)	ASBESTOS TYPE	ASBESTOS STRUCTURES	Sensitivity (str/cm^2)	CONCENTRATION (str/cm^2)	COMMENTS
1 *030509613-0001*	100	Chrysotile	<2.99	523	<1560	
2 *030509613-0002*	100	None Detected	<2.99	523	<1560	
3 *030509613-0003*	100	None Detected	<2.99	523	<1560	

Analyst(s)
Jim Hall (3)

Jose Arriaga
or other approved signatory

TEMMicro-1 THIS IS THE LAST PAGE OF THE REPORT. 1

NYC-WTC_000177269