



September 26, 2002

Mr. G. Foster Mills  
Managing Attorney  
New York City Law Department  
100 Church Street  
New York, New York 10007

**Re: Report of Ongoing Air Monitoring Performed On August 2, 2002**  
**TRC Project Number: 35052-0000-00011**

Dear Mr. Mills:

TRC Engineers, Inc. (TRC) performed air monitoring on August 2, 2002 in the space occupied by New York City Law Department and exterior to 100 Church Street as part of the ongoing air-monitoring program.

Representative samples for Metals, Asbestos, Carbon Dioxide, Carbon Monoxide, Temperature and Relative Humidity were collected outside and inside the building on the 4<sup>th</sup>, 5<sup>th</sup> and 6<sup>th</sup> floors.

Most results were below the analytical detection limit and all were below (i.e., better than) the respective Occupational Safety and Health Administration (OSHA) Permissible Exposure Limit (PEL). A copy of the test results along with OSHA permissible exposure limits for detected parameters is attached.

The results of this on-going sampling effort support and confirm TRC's recommendation in the April 8, 2002 Environmental Health Risk Assessment report to reoccupy the space.

Should you have any questions or comments, please feel free to contact us at (212) 563-3933.

Sincerely,

**TRC ENGINEERS, INC.**

A handwritten signature in black ink that reads 'Nitin Dave'.

Nitin Dave, CIH, CSP, PE  
Senior Project Manager

Enclosure

Cc: Mal Higgins – NYCLD  
Susan Kath - NYCLD