

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: **TRC Environmental Consultants**
1430 Broadway, 10th Floor
New York, NY 10018

Fax: (212) 221-7840 Phone: (212) 221-7822
 Project: **NEW YORK CITY LAW DEPARTMENT/ 100 CHURCH STREET, 6TH FLOOR RENOVATION**


Customer ID: **TRCE51**
 Customer PO:
 Received: **03/11/05 5:19 PM**
 EMSL Order: **030506590**
 EMSL Proj:
 Analysis Date: **3/14/2005**
 Report Date: **3/14/2005**

**Asbestos Analysis of Non-Friable Organically Bound materials by Transmission
 Electron Microscopy via NYS ELAP Method 198.4**

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON-ASBESTOS FIBERS	ASBESTOS TYPES	% TOTAL ASBESTOS
1 YELLOW MASTIC 030506590-0016	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Yellow Non-Fibrous Homogeneous	93.3	None	6.7 Chrysotile	6.7
1 BLACK MASTIC 030506590-0017	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
2 YELLOW MASTIC 030506590-0018	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Not Analyzed				
2 BLACK MASTIC 030506590-0019	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1
3 YELLOW MASTIC 030506590-0020	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Not Analyzed				
3 BLACK MASTIC 030506590-0021	9X9 FT & MASTIC TAN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
4 YELLOW MASTIC 030506590-0022	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Yellow Non-Fibrous Homogeneous	99.4	None	<1 Chrysotile	<1
4 BLACK MASTIC 030506590-0023	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	99.6	None	<1 Chrysotile	<1

Analyst(s)

Jim Hall (9)
 Rey Cross (6)



Jose Arriaga
 or other approved signatory

This laboratory is not responsible for % asbestos in total sample when the residue only is submitted for analysis. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.
 ACCREDITATIONS: NVLAP #101048-9 and NY STATE ELAP #11506

NYTNOB-2

1

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com**EMSL**

Attn: **TRC Environmental Consultants**
1430 Broadway, 10th Floor
New York, NY 10018

Fax: (212) 221-7840 Phone: (212) 221-7822

Project: **NEW YORK CITY LAW DEPARTMENT/ 100 CHURCH STREET, 6TH FLOOR RENOVATION**

Customer ID: TRCE51
 Customer PO:
 Received: 03/11/05 5:19 PM
 EMSL Order: 030506590
 EMSL Proj:
 Analysis Date: 3/14/2005
 Report Date: 3/14/2005

**Asbestos Analysis of Non-Friable Organically Bound materials by Transmission
 Electron Microscopy via NYS ELAP Method 198.4**

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON-ASBESTOS FIBERS	ASBESTOS TYPES	% TOTAL ASBESTOS
5 030506590-0024	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Yellow Non-Fibrous Homogeneous	96.5	None	3.5 Chrysotile	3.5
5 030506590-0025	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
6 030506590-0026	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Not Analyzed				
6 030506590-0027	9X9 FT & MASTIC GREEN 6TH FL LIBRARY	Black Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1
10 030506590-0007	12X12 FLOOR TILE GRAY 6TH FL COPY ROOM	Gray Non-Fibrous Heterogeneous	100.0	None	<1 Chrysotile	<1
11 030506590-0008	12X12 FLOOR TILE GRAY 6TH FL COPY ROOM	Gray Non-Fibrous Heterogeneous	99.7	None	<1 Chrysotile	<1
12 030506590-0009	12X12 FLOOR TILE GRAY 6TH FL COPY ROOM	Gray Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	

Analyst(s)

Jim Hall (9)

Rey Cross (6)



Jose Arriaga
 or other approved signatory

This laboratory is not responsible for % asbestos in total sample when the residue only is submitted for analysis. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.

ACCREDITATIONS: NVLAP #101042-2 and NY STATE ELAP #11506

NYTNOB-2

THIS IS THE LAST PAGE OF THE REPORT.

2