

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8
Sample Date :	11/14/2002	11/14/2002	11/14/2002	11/14/2002	11/14/2002	11/14/2002	11/14/2002	11/14/2002
Start Time:	14:00	14:03	14:07	14:11	14:15	14:22	14:30	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	
Location:	Center of East Office Space	S/E Side Office Room	Center of South Office Room	Southwest Side Office Room	Center of West Office Room	Northwest Side Office Room	North Side	Field Blank
CONSTITUENTS								
ASBESTOS (structures/mm ²)	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<16.7	Not analyzed

< Indicates less than the limit of quantification.

70 structures/mm² = AHERA re-occupancy criteria for school children