

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8
Sample Date :	11/21/2002	11/21/2002	11/21/2002	11/21/2002	11/21/2002	11/21/2002	11/21/2002	11/21/2002
Start Time:	13:50	13:54	13:57	13:59	14:05	14:12	14:20	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	
Location:	Office Room Center of South	Office Room Southeast Side	Office Room Center of West	Office Room Northwest Side	Office Room- Center of North	Office Room Southwest Side	West Side	Field Blank
CONSTITUENTS								
ASBESTOS (structures/mm ²)	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	Not analyzed

< Indicates less than the limit of quantification.

70 structures/mm² = AHERA re-occupancy criteria for school children