EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018
Fax: (212) 221-7840 Phone: (212) 221-7822
Project: **35052-0000-00020 / New York City Law Department / 100 Church St. 4th Floor Server Room**

Customer ID: TRCE51
Customer PO:
Received: 07/17/03 3:08 PM
EMSL Order: 030313033
EMSL Project ID:
Analysis Date: 7/18/03

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume (Liters)	Area Analyzed (mm^2)	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5μ < 5	# Structures ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm^2)	Asbestos Concentration (S/cc)	Notes
NA071703ASBAIR01 *030313033-0001*	1350.00	0.0600	0	None Detected			0.0048	**<16.67**	**<0.0048**	
NA071703ASBAIR02 *030313033-0002*	1341.00	0.0600	0	None Detected			0.0048	**<16.67**	**<0.0048**	

Analyst(s)
Jose Arriaga (2)

José Arriaga
Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm^2. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement. As per 40 CFR 763, the initial screening test may not be applied to samples with collected volumes of <1200 liters.
Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

THIS IS THE LAST PAGE OF THE REPORT.