

EMSL Analytical, Inc.

307 West 35th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSLAttn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: (212) 221-7822

Project: 35052-0000-00020 / 100 Church St./ New York City Law
Department / Revised Report: 7/24/03

Customer ID: TRCE51

Customer PO:

Received: 07/17/03 2:59 PM

EMSL Order: 030313040

EMSL Project ID:

Analysis Date: 7/20/2003


Asbestos Analysis via Transmission Electron Microscopy ASTM Method D5755-95

SAMPLE ID	AREA SAMPLED (cm ²)	ASBESTOS TYPE	ASBESTOS STRUCTURES	Sensitivity (str/cm ²)	CONCENTRATION (str/cm ²)	COMMENTS
NA071703ASBM V01 030313040-0001	100	None Detected	<4	951.515	<3806.060	
NA071703ASBM V02 030313040-0002	100	Chrysotile	<4	951.515	<3806.060	
NA071703ASBM V03 030313040-0003	100	None Detected	<4	747.619	<2990.480	
NA071703ASBM V04 030313040-0004	100	Chrysotile	7	837.333	5861.330	
NA071703ASBM V05 030313040-0005	100	None Detected	<4	951.515	<3806.060	
NA071703ASBM V06 030313040-0006	100	None Detected	<4	951.515	<3806.060	

Note: Sample # NA071703ASEMV06 was added to the report.

Analyst(s)

Mike Mengason (6)

Laboratory Manager
or other approved signatory

This above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.

TEMMicro-1

THIS IS THE LAST PAGE OF THE REPORT.

1