

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0050 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840 Phone: (212) 221-7822

Project: 35052-0000-00020 / New York City Law Department / 100
Church St. 4th Floor Server Room

Customer ID: TRCE51
Customer PO:
Received: 07/17/03 3:08 PM

EMSL Order: 030313033
EMSL Project ID:


Analysis Date: 7/18/03

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5μ < 5 ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
NA071703ASBAI R01 030313033-0001	1350.00	0.0600	0	None Detected		0.0048	<16.67 <0.0048	
NA071703ASBAI R02 030313033-0002	1341.00	0.0600	0	None Detected		0.0048	<16.67 <0.0048	

Analyst(s)

Jose Arriaga (2)



Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement. As per 40 CFR 763, the initial screening test may not be applied to samples with collected volumes of <1200 liters.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11508

TEMAHERA-1

THIS IS THE LAST PAGE OF THE REPORT.

1