

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Andrew Gasparro
JLC Environmental Consultants, INC.

Received: 4/4/03 12:30:00 PM
ATC Group #: 9620
Analysis Date: 4/4/03

Fax: (212) 420-6092 Phone: (212) 420-8119

Project: DEP Project #: 03-2744
114 Liberty Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA/MODIFIED AHERA)**

Sample	Volum	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Total Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Asbestos Concentration (S > 5µ/cc)
01 9620 -1	3650.40	0.2360	0	AMOSITE	0 1	0.0004	4.24	0.0004	0.0004
02 9620 -2	3650.40	0.2360	0	None Detected	0 0	0.0004	<4.24	<0.0004	< 0.0004
03 9620 -3	3650.40	0.2360	0	AMOSITE	0 1	0.0004	4.24	0.0004	0.0004
04 9620 -4	3650.40	0.2360	0	CHRYSTILE	1 0	0.0004	4.24	0.0004	< 0.0004
05 9620 -5	3650.40	0.2360	0	None Detected	0 0	0.0004	<4.24	<0.0004	< 0.0004

ROMAN PEYSAKHOV

Analyzed by:

MILENA LOWD

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Friday, April 04, 2003

Page 1 of 1