

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Andrew Gasparro
JLC Environmental Consultants, INC.

Received: 4/4/03 7:30:00 PM
ATC Group #: 9625
Analysis Date: 4/7/03

Fax: (212) 420-6092 Phone: (212) 420-8119

Project: DEP Project #: 03-2744
114 Liberty Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
010476 9625 -1	3643.00	0.2473	0	AMOSITE	2 1	0.0004	16.18 0.0017	
				CHRYSTOTILE	0 1			
010477 9625 -2	3643.00	0.2473	0	AMOSITE	0 1	0.0004	4.04 0.0004	
010478 9625 -3	3643.00	0.2473	0	None Detected	0 0	0.0004	<4.04 <0.0004	
010479 9625 -4	3643.00	0.2473	0	None Detected	0 0	0.0004	<4.04 <0.0004	
010480 9625 -5	3643.00	0.2473	0	None Detected	0 0	0.0004	<4.04 <0.0004	

MARK PEYSAKHOV

Analyzed by:

MILENA LOWD.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Monday, April 07, 2003

Page 1 of 1