

ATC ENVIRONMENTAL, INC.
104 East 25th Street
New York, NY 10010

APPROVED NY STATE DOH ELAP # 10879
ACCREDITED NVLAP Lab Code # 1187

Summary of TEM Results

N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Mr. Bernard Orlan

DATE: 10/28/01

Project/Site Identification: New Stuyvesant H.S., 345 Chambers St., NY, NY
Exterior & Interior of Building & Roof

CONCLUSION:

STATISTICAL SUMMARY

1) Inside Samples

TEM#	Project #	Volume (l)	<u>Asbestos Concentration</u>		
			S/mm ²	S/cc	ngm/m ³
5784- 62386	1	1920	0.0	0.0045 *	
5784- 62387	2	1928	0.0	0.0044 *	
5784- 62388	3	1936	0.0	0.0044 *	
5784- 62389	4	1944	0.0	0.0044 *	
5784- 62393	8	1936	0.0	0.0044 *	
5784- 62394	9	1928	0.0	0.0044 *	
5784- 62395	10	1928	0.0	0.0044 *	
5784- 62399	14	1928	0.0	0.0044 *	
5784- 62400	15	1928	0.0	0.0044 *	
5784- 62402	17	1936	0.0	0.0044 *	
5784- 62403	18	1928	0.0	0.0044 *	
5784- 62404	19	1928	0.0	0.0044 *	
5784- 62405	20	1928	0.0	0.0044 *	
5784- 62406	21	1936	0.0	0.0044 *	
Average=			0.0	0.0044	0

2) Outside Samples

TEM#	Project #	Volume (l)	<u>Asbestos Concentration</u>		
			S/mm ²	S/cc	ngm/m ³
5784- 62390	5	1944	0.0	0.0044 *	
5784- 62391	6	1944	0.0	0.0044 *	
5784- 62392	7	1936	0.0	0.0044 *	
5784- 62396	11	1944	0.0	0.0044 *	
5784- 62397	12	1936	0.0	0.0044 *	
5784- 62398	13	1920	0.0	0.0045 *	
5784- 62401	16	1936	0.0	0.0044 *	
Average=			0.0	0.0044	0

3) Blanks

TEM#	Project #	<u>Asbestos Concentration</u>		
		S/mm ²	S/cc	ngm/m ³
5784- 62407	22	- - - - -	Not Analyzed	- - - - -
5784- 62408	23	- - - - -	Not Analyzed	- - - - -
5784- 62409	24	- - - - -	Not Analyzed	- - - - -
Average=		N/A	N/A	N/A


4) Value of T - Statistic : N/A

* None detected; concentration equivalent to analytical sensitivity assigned.

This test report relates only to the specific items cited in the analysis.

The analysis was carried out according to the approved TEM method. The laboratory is in compliance with the quality specified for the method.

This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.



CONFIDENTIAL,

CITY_21MC100_003473419

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Analyzed by:
Roman Peysakhov

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

CONFIDENTIAL,

CITY_21MC100_003473420

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008