

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 14:00LOCATION PS 234 MDATE 2/18/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside Main Entrance						7	
" NE Corner						8	
" NW "						9	
" SW "						8	
" SE "						7	
Main Foyer						16	
Hall by Stair 2						12	
By Main Desk						14	
Office						9	
Cafeteria						7	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 2/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444350

ATC ASSOCIATES, INC.

Page 3 of 6

INDOOR AIR QUALITY FIELD REPORT

TIME 14:30LOCATION PS 234 M DATE 2/18/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Gym						10	
Gym						8	
Hall by Elevator						8	
108						8	
Hall by Exit 1						8	
114 (Hall)						8	
116						10	
118						7	
120						7	
122						6	
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 2/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444351

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1440LOCATION PS 234 M DATE 2/18/02 PROJECT NO. 19125-279

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
^{1st FL.} Stair # 3						8	
^{1st FL.} Hall by Stair 3						7	
222						5	
220						6	
220 (Hall)						6	
218						5	
216						9	
212 (Hall)						7	
224 (Hall)						10	
229						6	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 2/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444352

ATC ASSOCIATES, INC.

Page 4 of 6


INDOOR AIR QUALITY FIELD REPORT

TIME 1500LOCATION PS 234 M DATE 2/12/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
227 (Hall)						9	
210 (Hall)						9	
Hall by stairs						9	
225						6	
223						5	
221 (Hall)						8	
219						7	
206						7	
215						8	
211 (Hall)						7	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/12/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444353


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 15a0LOCATION PS 234 M DATE 2/18/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
211						7	
207 (Hall)						8	
Hall by #2						8	
201						7	
202						7	
201 (Hall)						7	
2nd FL - Stair #2						7	
301						10	
301 (Hall)						8	
302						7	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/19/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444354


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1545LOCATION PS 234 M DATE 2/18/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
305						6	
304						7	
311						5	
306						7	
315						8	
308						10	
309						12	
316						8	
314 320						7	
322						6	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444355