

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3TIME 10:00LOCATION PS 234 M DATE 1/25/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside (East)	—	46.1	20.1	458	1	27	0
Outside (North)	—	46.3	23.5	460	0	28	0
Outside (South)	—	46.1	25.0	455	0	21	0
Outside (West)	—	45.6	27.1	436	0	20	0
Main Entry <i>By Cust OFF. 4</i>	—	67.7	25.0	650	0	30	0
General Office.	5	73.7	21.0	618	0	28	0
Hall by Main Desk	—	66.1	23.8	620	0	28	0
Cafeteria	—	66.9	24.0	608	0	29	0
116	—	64.3	23.0	493	0	19	0
118	—	65.5	23.5	491	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444701


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3TIME 10:30LOCATION PS 234 M DATE 1/25/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
220	—	64.8	30.8	624	0	20	0
216	—	65.6	31.0	591	0	20	0
Hall by 212	—	66.0	31.0	605	0	21	0
229	—	66.9	31.3	607	0	19	0
225	—	67.5	31.5	569	0	19	0
210	—	67.3	31.0	579	0	23	0
219	—	68.4	30.8	670	0	18	0
206 (ASSEMBLY)	—	67.3	31.0	740	0	19	0
211	—	68.0	31.0	888	0	21	0
202	—	67.6	31.0	840	0	22	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444702

ATC ASSOCIATES, INC.

Page 3 of 3TIME 11:00

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 234 M DATE 1/25/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
(3rd Fl.) Stair #2		65.4	26.1	686	0	24	0
301		65.1	30.6	670	0	26	0
305		65.2	33.4	620	0	30	0
Hall by 309		65.5	24.1	728	0	29	0
304		65.8	34.2	775	0	29	0
306		66.1	32.6	790	0	29	0
308		65.1	33.4	890	0	22	0
319		65.4	31.7	790	0	22	0
316		64.8	31.9	827	0	17	0
318		64.5	32.7	790	0	28	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ji Cai Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444703