

ATC ASSOCIATES, INC.

Page 1 of 3TIME 13:00

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 234 MDATE 1/25/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside North		49.3	21.6	460	0	15	0
Outside South		48.0	22.2	444	0	11	0
Outside East		49.1	17.4	461	0	15	0
Outside West		47.1	22.4	456	0	16	0
III		71.9	31.8	561	0	14	0
General Office	7	72.5	19.5	550	0	16	0
Gym (1st Fl.)		68.3	23.6	596	0	18	0
Hall By Exit 1		69.1	22.2	595	0	18	0
By Main desk		67.5	20.7	502	0	19	0
Hall by West Exit		69.0	22.1	568	0	17	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chang Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444704

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3TIME 13:20LOCATION PS 234 MDATE 1/25/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301		66.5	31.2	585	0	18	0
302		65.5	31.1	800	0	20	0
305		65.3	32.7	649	0	22	0
311		66.0	31.6	640	0	19	0
315		66.0	29.0	610	0	19	0
Hall by Elevator		66.3	26.1	572	0	17	0
323		65.2	25.1	570	0	20	0
Hall by Stair 1		65.0	26.3	554	0	18	0
320		62.8	28.5	730	0	19	0
322		62.3	29.2	716	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jay Chen Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_00344705

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3TIME 13:40LOCATION PS 234 M DATE 1/25/02 PROJECT NO. 19125-279

Location	Occup:	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
222	-	63.1	30.7	583	0	20	0
220 (Hall)		64.0	31.0	585	0	21	0
220		64.4	31.4	630	0	21	0
216		64.9	31.5	583	0	19	0
227 (Hall)		66.5	31.1	554	0	16	0
223		67.1	29.5	539	0	19	0
219		67.7	29.8	564	0	19	0
206 (Assembly)		66.5	30.2	664	0	17	0
211		66.9	30.0	591	0	17	0
Stair # 2		66.6	30.0	626	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *Jim Chen* Date: 1/25/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444706