

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3

TIME 14:00

LOCATION PS 234 M

DATE 1/30/02

PROJECT NO. 19125-279

Location	Occup:	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside Main Entrance		62.4	48.3	463	0	13	0
Outside NW corner		62.0	49.1	465	0	19	0
Outside NE corner		62.3	48.5	469	0	21	0
Outside SE corner		61.9	48.3	475	0	15	0
Outside SW corner		61.7	49.3	501	0	19	0
Cafeteria		73.3	38.0	603	0	42	0
101A		75.7	39.0	659	0	40	0
General Office		75.3	38.5	611	0	41	0
Gym (1st Fl)		71.8	36.4	579	1	43	0
118		69.7	38.1	630	1	45	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: _____

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444737

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3


TIME 14:20

LOCATION PS 234 M DATE 1/20/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
220		67.7	38.0	639	0	40	0
218		69.6	41.9	709	0	41	0
216		69.9	41.6	811	0	40	0
229		69.4	39.4	711	0	42	0
225		70.3	40.1	800	0	43	0
223		71.2	41.8	709	0	40	0
215		72.0	42.8	801	0	45	0
211		72.4	41.7	909	0	50	0
Assembly		70.5	37.4	809	0	43	0
Stair #2		69.8	39.6	841	0	45	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/20/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444738

ATC ASSOCIATES, INC.

Page 3 of 3


INDOOR AIR QUALITY FIELD REPORT

TIME 14:50LOCATION PS 234 M DATE 1/30/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
305		69.7	41.5	909	1	42	0
309 (Hall)		70.4	41.8	879	1	49	0
311		70.3	41.0	900	1	50	0
315		70.4	41.4	1102	1	49	0
319		70.4	42.3	1142	1	48	0
323		69.7	41.8	983	1	47	0
325		68.7	41.5	938	1	47	0
312 (Hall)		68.5	41.4	990	1	46	0
318		68.2	41.1	971	0	48	0
322		66.9	41.2	925	0	46	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/30/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444739