

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of TIME 11:00LOCATION VariousDATE 12-10-07PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cafeteria		64.6	41.5	452	1	40	0.0
R. 118		67.7	38.7	457	2	33	0.0
Hallway 2nd fl. East side		70.2	38.6	418	1	18	0.0
R. 315		71.4	39.2	414	1	21	0.0
Roof by intake		71.0	32.6	437	1	54	0.0
back yard		69.0	31.9	441	1	48	0.0
playground							
front yard		63.6	34.4	446	1	45	0.0
court							
Main entrance outdoor		60.8	41.0	421	1	51	0.0
Guideline levels ASHRAE/AHIA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. MediacB Date: 12-10-07

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444813

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page __ of __

TIME 11:00LOCATION various DATE 12-10-01 PROJECT NO. 19125-0279

Location	Occup.	Wind Direction	Sulfur Dioxide	Hydrogen Sulfide	Nitric Oxide	Nitrogen Dioxide
Cafeteria			0.0	0	0.0	0.2
R. 118			0.0	0	0.0	0.2
Hallway 2nd fl. East side			0.0	0	0.0	0.6
R. 315			0.0	0	0.0	0.3
Roof by intake		W	0.0	0	0.0	0.2
backyard playground		W	0.0	0	0.0	0.2
front yard court		W	0.0	0	0.0	0.3
Main entrance art doors		W	0.0	0	0.0	0.5

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. McCreesh Date: 12-10-01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444814

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page __ of __

TIME 4:00LOCATION variousDATE 12-10-01PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Cafeteria		72.1	37.3	519	1	33	0.0
R.118		71.4	35.2	477	1	43	0.0
Hallway and St. East Side		71.3	35.0	455	1	25	0.0
R.315		72.0	36.6	541	1	55	0.0
Roof by intake		68.3	34.2	424	1	61	0.0
back playground back door		65.8	33.0	408	1	46	0.0
front yard court outdoor		59.5	34.8	404	1	45	0.0
Main entrance outdoor		57.9	40.3	413	0	30	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. MedinehDate: 12-10-01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444815

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page __ of __

TIME 4:00LOCATION VariousDATE 12-10-01PROJECT NO. 19125-0279

Location	Occup.	Wind Direction	Sulfur Dioxide	Hydrogen Sulfide	Nitric Oxide	Nitrogen Dioxide
Cafeteria			0.0	0	0.0	0.3
R.118			0.0	0	0.0	0.4
Hallway 2nd fl. East side			0.0	0	0.0	0.3
R.315			0.0	0	0.0	0.3
Roof by intake			0.0	0	0.0	0.2
back playground outdoor			0.0	0	0.0	0.4
front yard Court outdoor			0.0	0	0.0	0.3
Main Entrance outdoor			0.0	0	0.0	0.6

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: M. Medinich Date: 12-10-01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003444816