

ATC ASSOCIATES INC.

BATCH NO.

19891**BULK SAMPLE DATA AND CHAIN OF CUSTODY FORM****PROJECT INFORMATION**

1. Client: NYC - BOE	2. Project Name: AHERA REINSPECTION	3. Project # 14584-0823	4. Project Manager: ANDREAS ANDREOU
2a. Project Address: 292 Greenwich street, New York, NY10007		4a. Investigator: Y. Efstathiou	
5. Date: <u>1/2/02</u>	6. Building Name: P.S. 234M	8. Turnaround Time: ☐ STAT ☐ 24 HRS ☐ 72 HRS ☒ OTHER <u>RUSH</u>	9. Comments (Field): <u>Rush</u>
7. Sampling Areas: Entire		☐ 6 HRS ☐ 48 HOURS ☐ NORMAL	10. Time in / Time out:

H.A.#	SAMPLE ID NUMBER	MATERIAL DESCRIPTION	LOCATION	FLOOR NUMBER	RESULTS
	PS 234M - 1/2 - <u>01</u> Tape - Asbestos	Settled Dust	Flur Room #312 - West side	3rd	No ASBESTOS FIBERS WERE DETECTED
	PS 234M - 1/2 - <u>02</u> Tape - Asbestos	Settled Dust	Flur Room #212 - East side	2nd	↓
	P.S. 234M - 03 <u>1/2</u> Tape - Asbestos	Settled Dust	Flur Room on Roof - Northeast side	Roof	↓

CHAIN OF CUSTODY

17. Relinquished By: <u>Jeanne Efstathiou</u>	18. Date: <u>1/2/02</u>	19. Time:	20. Received By: <u>Michelle</u>	21. Date: <u>1/2/02</u>	22. Time: <u>16:30</u>	23. Method of Submittal: ☐ FIELD ☐ WALK IN ☐ US MAIL ☐ FED-X ☐ OTHER

LAB INFORMATION

24. Name and Signature: <u>Michelle</u>	25. Date: <u>1/2/02</u>	26. Time: <u>17:00</u>	27. Comments (Lab): <u>3 PLM 6</u>
24a. Analyzed By:			
24b. Analyzed By:			
24c. QC By:			